



Security Bulletin for XONA Critical Systems Gateway (CSG)

Bulletin ID	Date Published	Severity
XONA21-10	April 2, 2021	Low

Summary

During a recent 3rd party security assessment of the CSG it was discovered that the CSG serial port was open as default and there was no way to disable it.

Affected Products

Product	Version	Hardware
XONA Critical Systems Gateway (CSG)	3.2 and earlier	ML-350

Solution

The CSG now has an option to disable the serial port from the admin account. A security update for this issue is available in the 3.3.2 release update file, released in Apr 2021. To receive this update, login to your support portal account on the XONAsystems.com website or contact us for assistance by email: support@xonasystems.com.