



Security Bulletin for XONA Critical Systems Gateway (CSG)

Bulletin ID	Date Published	Severity
XONA21-11	April 2, 2021	Low

Summary

A new CVE was reported that affected SUDO operations within the CSG. Its CVE-2021-3156

Affected Products

Product	Version	Hardware
XONA Critical Systems Gateway (CSG)	3.2 and earlier	ML-350

Solution

CVE-2021-3156 had been mitigated in the CSG. A security update for this issue is available in the 3.3.2 release update file, released in Apr 2021. To receive this update, login to your support portal account on the XONAsystems.com website or contact us for assistance by email: support@xonasystems.com.